



KAA/OT/MIA/0036/2024-2025

11th November, 2024

To: All Tenderers

**TENDER NAME: B I D D I N G D O C U M E N T S F O R
P R O C U R E M E N T O F T H E P R O P O S E D
R E H A B I L I T A T I O N O F P A V E M E N T S , A I R F I E L D
G R O U N D L I G H T I N G A T M O I I N T E R N A T I O N A L
A I R P O R T , M O M B A S A**

TENDER NO: KAA/OT/MIA/0036/2024-2025

ADDENDUM NO. 3

The following are tender clarifications/addendum issued regarding the above tender in accordance to instructions to tenderers clause ITB 8.1 of the bidding document for the referenced tender.

No.	Clarification	Response
1.	Weather the 11kV cables are lead sheathed or Cu/XLPE/SC/SWA/PVC as both are in the specification (as highlighted above). kindly clarify	XLPE/SC/SWA/PVC. The Specifications are for broader understanding while the BoQ are specific.
2.	Advice on the size of the earth cable for 50mm ² 3 core (RBY) + 1 core earth cable XLPE armored copper cable as highlighted	The “50mm ² 3 core (RBY) + 1 core earth cable XLPE armored copper cable” to read “50mm ² 3 core (RBY) XLPE/SC/SWA/PVC armour copper cable.....”
3.	The Authority wish to amend Vol II of IV – for the BOQ; by replacement in its entirety as Appendix I	
4.	The Authority wish to amend Vol IV of IV – for the Technical Specifications – by Replacement of pages 198 to 203 as Appendix 2.	

The closing/opening date remains **14th November, 2024 at 11.00 a.m.**

Kindly ensure your tender is valid for a period of **126 days** and your tender security is valid for a period of **156 days** from the closing/opening date of **14th November, 2024** at **11.00. a. m.**

This addendum forms part of the bidding document and is binding on all bidders. All other conditions remain the same.



Vincent Korir
GM (PROCUREMENT AND LOGISTICS)
For: MANAGING DIRECTOR/CEO D.K